

Indian Institute of Management Raipur
GEC Campus, Sejbahar, Raipur 492015, India

Date: 13.08.2018

Reply to the Prebid queries

With reference to NIT No:3/P-1 Campus/IIMR/2018-19, dated 28.07.2018 for the work of "Development of Phase 1 Campus including Buildings for IIM Raipur at Naya Raipur SH: Auditorium Chair, the Prebid query replies is made, which is appended in annexure A.



REPLY TO PREBID QUERIES FOR AUDITORIUM CHAIR

SL.No./ Item No.	Description	Pre-Bid Points	Reply
1	BIFMA certification to be uploaded	Since BIFMA doesn't give any certifications, there is no meaning for the same. We request for removal of the line	Chair manufacturer shall have the membership of BIFMA and the same shall be uploaded.
2	The chair back & seat cover shall be thermoplastic and armrest shall be melamine polished solid wood	Either Handles, seat and back cover shall be thermoplastics OR Seat cover, handles and back cover in wooden finish OR Seat cover & handles in wooden finish and back with fabric	No change
3	Framework shall be steel tube confirming to IS-3071:2005. Test certificate of steel tube confirming to IS-3074 shall be uploaded.	If the specification of steel can be given.	"Framework shall be steel tube confirming to IS-3071:2005" shall be read as "Framework shall be steel tube confirming to IS-3074:2005". The steel tube shall be ERW-Grade I and minimum thickness of tube shall be 1.2 mm.
4	Commercial	Being an agent of reputed manufacturer, can we quote on behalf of them. We will be facilitating to quote to the manufacturer and the manufacturer will directly supply materials.	No change
5	Commercial	Request for clarity on terms of payment	Payment term is clearly specified in the tender document.
6	Regarding EMD & Tender cost	As per the Public Procurement Policy for MSEs order 2012 dated 23rd March 2012, clause no.10, Organisations registered with MSME are eligible for free of cost tender set and are exempted from EMD	MSME registered bidders possessing valid enlistment certificate from NSIC are not required to submit any Bank Draft towards EMD and Cost of Tender. However, the enlistment certificate shall be valid as on date of opening of tender and bidders shall upload the same. The bidder not having valid enlistment certificate on the date of opening of tender will not qualify for the opening of technical bid. The original affidavit in Form 'P' shall be submitted on or before last date and time of submission of tender.

Note:- This prebid clarification will form part of the tender document. Rates shall be quoted after taking into consideration of the above modifications.

